SEPURA™

Quality Control check sheet

for SEPURA ST/D oil-water separators

Perform weekly checks

Date	Tested by	OK?	Date	Tested by	OK?	Date	Tested by	OK?

Taking a sample. Remove cap from test point and fill sample jar. Hold jar and the test strip side by side to judge cloudiness. The step on the test that most closely equates to the sample indicates approximately the oil content (as marked on the strip). This is an indication only. For a precise hydrocarbon content test, ask your supplier to contact Bowman Stor Ltd.

Under normal operating conditions your filter set should last around 4000 running hours, until the outlet cloudiness indicates an oil content of no more than 10ppm, at which point a service is essential. Please note that due to fluctuations in operating and climatic conditions; various compressor and lubricant combinations; the service condition of compressors and sundry other factors, this period WILL vary. For this reason checks should be carried out weekly and replacement filter kits ordered in readiness from your normal supplier. Only use GENUINE SEPURA filters. Carbon alternatives will NOT provide the same performance and will invalidate your warranty.